

<b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>			1. CONTRACT ID CODE		PAGE OF PAGES 1   4		
2. MODIFICATION NO.:  0002		3. EFFECTIVE DATE  MAY 26, 2005		4. REQUISITION/PURCHASE REQ. NO.  W81W3G-2035-7181		PROJECT NO. (If applicable)	
6. ISSUED BY Department of the Army Baltimore District, Corps of Engineers Contracting Division P.O. Box 1715 Baltimore MD 21203-1715		CODE CA31		7. ADMINISTERED BY: Contracting Division, Contracts Branch CENAB-CT-C 10 S. Howard ST. Room 7000 Baltimore, MD 21203-1715		CODE E1P0100	
8. NAME AND ADDRESS OF CONTRACTOR (No., street, county, State and ZIP Code)				(x)		9A. AMENDMENT OF SOLICITATION NO. W912DR-05-R-0052	
				X		9B. DATED (SEE ITEM 11) MAY 18, 2005	
						10A. MODIFICATION OF CONTRACT/ ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					

**11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS**

	The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <b>is not extended.</b>
	<b>DATE OF RECEIPT OF PROPOSALS      4:00 PM, LOCAL TIME    JUN 17, 2005</b>

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods:

(a) By completing Items 8 and 15, and returning   1   copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

**12. ACCOUNTING AND APPROPRIATION DATA (If required)**

**13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS,  
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.**

	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER No. ITEM 10A
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR43.103(b)
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF: changes clause FAR 52.243.1
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor    is not,    is required to sign this document and return        copies to the issuing office.

**14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.)**

**BARRACKS COMPLEX, PHASE 1  
FORT MYER, VIRGINIA**

**SEE THE FOLLOWING PAGES**

Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect

15A. NAME AND TITLE OF SIGNER (Type or print)		16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)	
15B. CONTRACTOR/OFFEROR  _____ (signature of person authorized to sign)		16B. UNITED STATES OF AMERICA  BY _____ (Signature of Contracting Officer)	
15C. DATE SIGNED		16C. DATE SIGNED	

AMENDMENT NO. 0002 TO RFP W912DR-05-R-0052  
EFFECTIVE MAY 26, 2005

Items below do not apply to the HAZARDOUS MATERIALS ABATEMENT, BUILDINGS 402, 403 & 412 package added to the project by Amendment 0001.

SPECIFICATIONS:

1) Section 01050, Paragraph 1.14: Delete the text and salvage list, and substitute the following:

“The Contractor shall maintain adequate property control records for all materials and equipment specified to be salvaged. These records may be in accordance with the Contractor's system of property control, if approved by the property administrator. The Contractor shall be responsible for the adequate storage and protection of all salvaged materials and equipment and shall replace, at no cost to the Government, all salvage materials and equipment which are broken or damaged during salvage operations as the result of his negligence, or while in his care. The Contractor shall salvage the items below from Buildings 402 and 403. See Sheet Nos. CD101 and CD102 for notes on exterior salvageable items except for the chiller.

QUANTITY	DESCRIPTION
All	Electrical panels located on the 1st and basement floors (Building 402)
All	Free standing water fountains (Building 402)
All	Cabinets filled with new pneumatic controls, located in the basement mechanical room (Building 402)
1	Cooling Tower (Building 403)

The roof-mounted cooling tower shall be disconnected with care to ensure that it can be reused. All applicable environmental regulations must be followed in disconnecting the cooling tower. The cooling tower and other listed salvage items shall be transported to another location on Ft Myer as directed by the Contracting Officer and DPW, FMMC. (CENAB-EN-DT)”

2) Section 01510, Paragraph 1.3.3: Delete sentence, “The signs shall be 48” by 48”.” and substitute “The signs shall be 72” by 96”.”

AMENDMENT NO. 0002 TO RFP W912DR-05-R-0052  
EFFECTIVE MAY 26, 2005

- 3) Section 02510A, Paragraph 3.3.1: Delete this paragraph and substitute the following:

“3.3.1 Bacteriological Disinfection

Before acceptance of potable water operation, each unit of completed water line shall be disinfected as prescribed by AWWA C651. Valves on the lines being disinfected shall be open and closed several times during the contact period. Lines shall then be flushed with clean water until the chlorine residual is within 1 ppm of the normal residual level maintained in the existing water system. During the flushing period, each fire hydrant on the line shall be open and closed several times. After flushing, personnel from the Contractor's commercial laboratory shall take at least two water samples, and another round of samples spaced 24 hours apart, from two different locations approved by the Contracting Officer. Sample collection shall be in proper sterilized containers, and bacterial examination shall be performed in accordance with State approved methods. The commercial laboratory shall be certified by the State's approving authority for examination of potable water. The disinfection shall be repeated until bacterial results are satisfactory. The unit will not be accepted until satisfactory bacteriological results have been obtained.”

- 4) Section 15190A, Paragraph 3.1: Add the following sentence to the last paragraph: “All work associated with installation of exterior gas piping, up to and including the meter set assembly, provided by Washington Gas shall be at no cost to the Contractor. See Sheet MS101 for exceptions.”

DRAWINGS:

- 5) Sheet SF104C, Roof Framing Plan: Delete the note for top portion of roof reading “Standing Seam Metal Roof” and substitute “Modified Bitumen Roof Membrane.”
- 6) Sheet SF104C, Roof Framing Plan: Add the following note: “See Architectural Roof Plan on Sheet AE105C.”
- 7) Sheet EP104C, Basement Power Plan: Make the following changes to Room B06:
- a) Change BP1-19 and BP1-21 to IDS-3.
  - b) Change BP1-21 to IDS-5.
  - c) Change BP2-17 to IDS-2.
  - d) Change BP2-19 to IDS-4.

AMENDMENT NO. 0002 TO RFP W912DR-05-R-0052  
EFFECTIVE MAY 26, 2005

8) Sheet EP503C, Panel Schedule: Make the following changes:

- a) Change circuit 17 on panel BP2 to spare from DH-1, 2, & 3.
- b) Change circuit 19 on panel BP2 to spare from UH-24.

9) Sheet EP507C, Panel Schedule: Make the following changes:

- a) Change circuit 2 on panel IDS to DH-1, 2, & 3 from spare.
- b) Change circuit 3 & 5 on panel IDS to receptacles from spare.
- c) Change circuit 4 on panel IDS to UH-24 from spare.